



TYPE APPROVAL CERTIFICATE

Certificate no.:
TAE00003BA
Revision No:
1

This is to certify:

that the Instrument for Switchboard

with type designation(s)

FC3V "Serie Naval" and FC3VII "Serie Naval" (Frequency Meter)

issued to

SACI, S.A. - de Construcciones Industriales
Alcobendas, Madrid, Spain

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application:

Location classes:

Temperature: **B**

Humidity: **B**

Vibration: **A**

Products approved by this certificate are accepted for installation on all vessels classed by DNV.

Issued at **Høvik** on **2024-05-06**

for **DNV**

This Certificate is valid until **2028-12-31**.

DNV local unit: **Madrid**

Approval Engineer: **Nicolay Horn**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Form code: TA 251

Revision: 2023-09

www.dnv.com

Page 1 of 2

Product description

Frequency Meters

Type designation	Front dimensions (mm)	Protection degree	Frequency range (Hz)
FC3V "Serie Naval"	96 x 96	IP 54	46 - 54 or 56 - 64
FC3VII "Serie Naval"	96 x 96	IP 54	46 - 54 or 56 - 64 x 2

Ranges: 100/110/220/380/415/440V

Type Approval documentation

L.C.O.E. No. 89116165 & L.C.O.E. No. 89116166 dated 18.04 1990

Cetema EMC test report: 51507IEM.006 dated 28.11.1995

Tests carried out

Type tests in accordance with IEC 60051, EMC tests & Environmental tests (DNV-GL class guidelines CG-0339 - Environmental test specification for electrical, electronic and programmable equipment and systems).

Marking of product

SACI, type designation

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE